



A P P R O V A L S ®

# Certificate of Conformity/Approval

\*Addendum\*

**Certificate No.:** SAA101237EA

**Date of Issue:** 23 September 2020

**Regulatory Definition:** Miniature Overcurrent Circuit-Breaker

**Product Description:** Circuit Breaker

Additional Models	Trade Name	Rating/Marking
Ex9BH	Noark	Un= 240/415V~ (1P); or 230/400V~ (1P), 240V~ (1P+N); or 230V~ (1P+N), 415V~ (2P, 3P, 3P+N, 4P); or 400V~ (2P, 3P, 3P+N, 4P) In= 1, 2, 3, 4, 6, 8, 10, 13, 16, 20, 25, 32, 40, 50, 63A B, C or D type Ics=7500A, Icn=10000A
Ex9BS	Noark	Un= 240/415V~ (1P); or 230/400V~ (1P), 240V~ (1P+N); or 230V~ (1P+N), 415V~ (2P, 3P, 3P+N, 4P); or 400V~ (2P, 3P, 3P+N, 4P) In= 1, 2, 3, 4, 6, 8, 10, 13, 16, 20, 25, 32, 40, 50, 63A B, C or D type Ics=4500A, Icn=4500A

*R.A. Hill*


For and on Behalf of  
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and Certificate verification, go to:

[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 15-10-20 101237/2b  
Ratings corrected