



Product Service

CERTIFICATE

No. B 075006 0073 Rev. 01

Holder of Certificate: **NOARK Electrics (Shanghai) Co., Ltd.**

No.3857 Sixian Road, Songjiang District
201614 Shanghai
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product:

Moulded case circuit breaker

Model(s):

Ex9BD125

Parameters:

Rated insulation voltage U_i :	1200V
Rated impulse voltage U_{imp} :	8kV
Rated current I_n :	16A, 20A, 25A, 32A, 40A, 50A, 63A, 80A, 100A
Rated operational voltage U_e :	DC300V (1P appearance), DC600V (2P appearance)
Rated service short-circuit breaking capacity I_{cs} :	6kA
Rated ultimate short-circuit breaking capacity I_{cu} :	6kA
Selectivity category:	A
Type of overcurrent release:	Thermal magnetic

Tested according to: EN 60947-2:2017/A1:2020

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 704102148701-01

Valid until: 2027-09-19

Date, 2022-09-21

(Jie Zhu)